

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Lake Tamarack Water Fails to Meet Established Water Quality Parameter (WQP) Levels

Our water system recently violated a New Jersey drinking water requirement, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

Our water system has corrosion control treatment installed to help prevent lead and/or copper in the pipes from dissolving into the water. The corrosion control treatment was deemed optimized; and therefore, the New Jersey department of Environmental Protection (NJDEP) established optimal Water Quality Parameters (WQP) values, which are values the corrosion control treatment functions most effectively. We monitor for WQP values per federal regulations.

During the January 1, 2024 to June 30, 2024 monitoring period, our WQP sample results did not meet the optimal WQP values set by the NJDEP for 33 days, and the water system cannot be below the minimum pH level set by the NJDEP for more than nine (9) days. Lake Tamarack Water Company does not currently adjust pH as a component of the water treatment.

You were previously notified of this violation in public notice(s) issued on November 2, 2024. Per the federal Safe Drinking Water Act, we will continue to provide you with an updated public notice every 3 months until we complete all approved remedial measures and return to compliance with the optimal WQP values.

In addition to monitoring optimal WQP values, our water system routinely monitors for lead and copper. The most recent monitoring conducted January 1, 2024 to June 30, 2024; demonstrated we are in compliance with the Federal action levels for lead and copper. If there is a lead action level exceedance, you will be notified accordingly.

What does this mean?

This is not an emergency. If it had been, you would have been notified within 24 hours. This violation does not mean there is confirmed lead and/or copper in your drinking water. However, since corrosion control treatment is used to protect residents from lead and copper potentially leaching from internal pipes and solder, it is important to be aware of the health effects of lead and copper and steps you may take to reduce your exposure.

- Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.
- Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal physician.

If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about your drinking water.

Typically, lead and/or copper enters drinking water by leaching from pipes and plumbing components in homes. We have treatment installed to reduce the wearing away of lead and/or copper leaching from pipes and plumbing components into the water and optimal WQP values set to ensure effectiveness of the treatment. Failure to meet the set values requires us to evaluate the currently installed treatment and operation thereof and take actions necessary to meet the optimal WQP values.

What should I do?

You do not need to use an alternate water supply (e.g., bottled water). However, if you have specific health concerns, consult your doctor. Additionally, if you would like to reduce your potential exposure to lead and/or copper in drinking water, you may choose to take the following steps:

NJDEP, OWQP PN – TT Violation [October 2023]

- Run water to flush out lead and/or copper. Run water for 15 – 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking if it hasn't been used for several hours.
- Use cold water for cooking and preparing baby formula. Do not cook with or drink water from the hot water tap; Lead dissolves more quickly into hot water. Do not use water from the hot water tap to make baby formula.
- Do not boil water. Boiling water will not reduce lead and/or copper levels.
- Regularly remove and clean aerators/screens on plumbing fixtures. Over time, particles and sediment can collect in the aerator screen. Regularly remove and clean aerators screens located at the tip of faucets and remove any particles.

For additional steps you may take to reduce your exposure to lead in drinking water, see <https://www.state.nj.us/dep/watersupply/dwc-lead-consumer.html>.

What is being done?

We monitor for pH after the water has passed through treatment, and throughout the distribution system (i.e., at houses/buildings served by the Lake Tamarack water system), and report to NJDEP. The recent results indicated lower values which were below the established Corrosion Control Optimal Parameters. We anticipate resolving the problem by middle year as we will be sampling in June.

For more information, please contact Laketamarackwater@gmail.com.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Lake Tamarack Water Company. State Water System ID#: NJ 1911003.
Date distributed: 12/28/24.